

AQUA TECH ENTERPRISES

ISO 9001-2015

A House of Water Treatment

Sri Balaji Residency, Hebbagodi, Bommasandra Post, Hosur Road, Bangalore - 560 099.
Website : www.aquatechenterprises.com | E-mail: aquatechenterprises@gmail.com

Mobile: 9741785011, 9741785014, 9448052656, 9845151697

Date: 2.11.2023

To,
The Principal,
M/s: Army Public School,
PRTC, Bengaluru.

Analytical Report of Treated Water.

Source of water: R.O. Filter Water	Date of collection: 29/10/23
------------------------------------	------------------------------

Parameters	Result	Permissible limit
Turbidity	0.0 ppm	<5 ppm
PH	6.8	6.5-7.5
Iron	0.0 ppm	<0.3 ppm
Total Dissolved Solid	30 ppm	<500 ppm

Checked By: *glankar*

M. Mandal

(M. MANDAL)

Note: Result of above parameters are within the permissible limit of drinking water.